

IAPMO RESEARCH AND TESTING, INC.

5001 E. Philadelphia Street, Ontario, CA 91761-2816 • (909) 472-4100 • Fax (909) 472-4244 • www.iapmort.org



CERTIFICATE OF LISTING

IAPMO Research and Testing, Inc. is a product certification body in which its product certification system includes inspection and testing of samples taken from the supplier's stock or from the market or a combination of both to verify compliance to the requirements of applicable codes and standards. This activity is coupled with periodic surveillance of the supplier's factory and/or warehouses as well as the assessment of the supplier's Quality Assurance System. This listing is subject to the conditions set forth in the characteristics below and is not to be construed as any recommendation, assurance or guarantee by IAPMO Research and Testing, Inc. of the product acceptance by Authorities Having Jurisdiction.

Issued to:

OASIS INTERNATIONAL

222 EAST CAMPUS VIEW BLVD
COLUMBUS, OH 43235

Product:

Drinking Water Treatment Units - Emerging Compounds/Incidental Contaminants

Products are certified to the following standard(s):
NSF/ANSI 401-2020

File Number: WP-16474

Effective Date: June 2024

Revised Date: September, 12 2024

Void After Date: June 2029*




Chairman, Product Certification Committee


Chief Technical Service Officer

* This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

This listing period is based upon the last date of the month indicated on the Effective Date and Void After Date shown above. Any change in material, manufacturing process, marking or design without having first obtained the approval of the Product Certification Committee, or any evidence of non-compliance with applicable codes and standards or of inferior workmanship, may be deemed sufficient cause for revocation of this listing. Production of or reference to this form for advertising purposes may be made only by specific written permission of IAPMO Research and Testing, Inc. Any alteration of this certificate could be grounds for revocation of the listing. This document shall be reproduced in its entirety.

IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING



Issued To: OASIS INTERNATIONAL

File Number: WP-16474

Product: Drinking Water Treatment Units - Emerging
Compounds/Incidental Contaminants

Effective Date: June 2024

Revised Date: September, 12
2024

Void After: June 2029

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

Identification:

Product shall bear: The certified company name. The model number or trade designation. The appropriate certification mark. Product markings may be permanently fixed on the system or may be included as part of product literature or packaging.


Characteristics:

The point-of-use and point-of-entry systems addressed by this Standard are designed to be used for the reduction of specific substances that may be present in drinking water (public or private) considered to be microbiologically safe and of known quality. Certification demonstrates that all materials safety and structural integrity (as applicable) requirements have been met. To be used in accordance with the manufacturer's instructions.

Products listed on this certificate have been tested by an IAPMO R&T recognized laboratory. This recognition has been granted based upon the laboratory's compliance to the applicable requirements of ISO/IEC 17025.

IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING



Issued To: OASIS INTERNATIONAL

File Number: WP-16474

Product: Drinking Water Treatment Units - Emerging Compounds/Incidental Contaminants

Effective Date: June 2024

Revised Date: September 12, 2024

Void After Date: June 2029

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

Product Type

Plumbed-in

NOTE

All products in this listing are certified whether they bear the mark or not.

Brand Name	Model Number	Replacement Component	Flow Rate (GPM)	Capacity (Gallons)	Reduction Claims
OASIS	Pharmaceutical	041670-001	1.50	725	Microplastics, Atenolol, Carbamazepine, DEET, Metolachlor, Meprbamate, Trimethoprim, Bisphenol A, Estrone, Ibuprofen, Naproxen, Nonylphenol, Phenytoin

Product Type

Plumbed-in

NOTE

All products in this listing are certified whether they bear the mark or not.

Brand Name	Model Number	Replacement Component	Flow Rate (GPM)	Reduction Claims
OASIS	VersaFilter III	041145-001	1.50	Microplastics
OASIS	Outdoor	041667-001	1.50	Microplastics
OASIS	Total PFAS	041668-001	1.10	Microplastics